



5 Star Extinguisher Services

6/159 Chifley Street Wetherill Park NSW 2164

ABN: 55 209 172 495

P.O. Box 345 Toongabbie NSW 2146

Telephone: (02) 9609 7420 **Mobile:** 0413 283 150 **Facsimile:** (02) 9609 6303

INSPECTION PROCEDURES EMERGENCY LIGHTING

Reference: AS/NZS 2293-1:2293-2

Inspection Checks Include:

1. SIX MONTHLY INSPECTION:

- ✓ Make sure that no interruption to power supply within 16 hours discharge test.
- ✓ Replace luminaries and exit signs with tubular fluorescent lamps if they exhibit extensive end blackening, even when lamps still operate.
- ✓ Discharge Test. Manual or Automatic dependant on system.
- ✓ Clean all luminaries.
- ✓ Check luminaries are clearly numbered.
- ✓ Duration of test (battery life).
- ✓ Starter switch.
- ✓ Charge indicator.
- ✓ Test switch.
- ✓ Diffuser.
- ✓ Reflector.
- ✓ Fill out emergency lighting logbook in accordance with AS/NZS 2293-1.

2. TWELVE MONTHLY INSPECTION:

- ✓ As per 6 monthly inspection and test.